

# Certificate of Performance

On this date the cleanroom facilities of  
**Brentwood Industries**  
**CEMA Cleanroom**

Have been tested in accordance with NEBB Procedural Standards for  
Certified Testing of Cleanrooms to meet the following air cleanliness classification  
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.

Room Name	"At-Rest" Occupancy State	"Operational" Occupancy State
Gowning Room	ISO Class 7 @ 0.5 & 1.0 $\mu\text{m}$	ISO Class 7 @ 0.5 & 1.0 $\mu\text{m}$
Raw Material Room	ISO Class 7 @ 1.0 & 5.0 $\mu\text{m}$	ISO Class 7 @ 1.0 & 5.0 $\mu\text{m}$
Work Cell A	ISO Class 6 @ 0.3, 0.5 & 1.0 $\mu\text{m}$	ISO Class 6 @ 0.3, 0.5 & 1.0 $\mu\text{m}$
Work Cell B	ISO Class 6 @ 0.3, 0.5 & 1.0 $\mu\text{m}$	ISO Class 7 @ 0.5, 1.0 & 5.0 $\mu\text{m}$
Work Cell C	ISO Class 7 @ 5.0 $\mu\text{m}$	ISO Class 8 @ 0.5, 1.0 & 5.0 $\mu\text{m}$
Work Cell D	ISO Class 6 @ 0.5 $\mu\text{m}$	ISO Class 7 @ 1.0 $\mu\text{m}$
Quality Inspection & Analysis Area	ISO Class 6 @ 0.3 & 0.5 $\mu\text{m}$	ISO Class 7 @ 1.0 $\mu\text{m}$

NEBB Certified Firm: **Air Filtration Management, Inc.**

Phone: (610) 867-3869

[www.airfiltrationmgmt.com](http://www.airfiltrationmgmt.com)

NEBB Certification Number: 104

NEBB CPT Professional: **William M. Bock**

Signature: William M. Bock

Test Date: **April 2019** Retest Date: **April 2020**

National Environmental Balancing Bureau

